

Improving energy efficiency on ARCHER2

Adrian Jackson, Alan Simpson, Andy Turner

EPCC, The University of Edinburgh


www.archer2.ac.uk



Outline

- ARCHER2 service
- Efficiency priorities
- ARCHER2 power draw
- Reducing power draw/energy use
 - CPU power BIOS setting
 - Default CPU frequency
- Lessons learned and summary

ARCHER2 Partners



THE UNIVERSITY
of EDINBURGH



**Hewlett Packard
Enterprise**

This work was partially funded by the UKRI Digital Research Infrastructure Net Zero Scoping Project (NE/W007134/1) <https://net-zero-dri.ceda.ac.uk/>

ARCHER2 Technology

- HPE Cray EX Supercomputer
- 5,860 compute nodes
 - 750,080 CPU compute cores
- HPE Slingshot 10 interconnect
- Compute nodes:
 - Dual socket AMD EPYC™ 7742 Processors, 64c, 2.25 GHz
 - 256 GiB / 512 GiB memory per node
 - Two 100 Gbps HPE Slingshot 10 interfaces per node
- 4x ClusterStor L300 Lustre file systems, each 3.6 PB
- 1 PB ClusterStor E1000F solid state storage
- 4x NetApp FAS8200A file systems, 1 PB total





- UK National Supercomputing Service – based at EPCC at The University of Edinburgh
- Service designed to enable world-leading research for a wide range of research areas in the UK
- User base of over 3000 users

Application Type	Approx. % Use	Example Applications
Quantum Materials Modelling	40%	CASINO, CASTEP, CP2K, QE, VASP
Earth Systems Modelling	20%	Met Office UM, MITgcm, NEMO, WRF
Computational Fluid Dynamics	15%	OpenFOAM, Nektar++, SBLI, Code_Saturne
Biomolecular Modelling	15%	GROMACS, NAMD
Classical Materials Modelling	5%	LAMMPS
Plasma Physics	3%	EPOCH, GS2, OSIRIS
Quantum Chemistry	2%	NWChem, GAMESS

- Huge range of software: top 10 codes ~50%, top 40 ~75% plus 100s of others

Barbara Farkas

Efficiency priorities



Different sites have different priorities



- Priorities and motivations vary between sites, and may include:
 - Reducing running costs
 - Reducing carbon emissions
 - Reducing energy use
 - Power demand control to improve integration between HPC centres and energy grids
 - Educating and enabling users to be energy-aware
 - Fair attribution of actual costs
- Different efficiency targets means different operational decisions
- Doing the “right” thing can be complicated

Carbon emissions vs energy



- Understanding carbon emissions is increasingly important for HPC in the context of reducing worldwide limits on such emissions
- A significant component of HPC emissions already comes from embodied emissions (from manufacture, delivery, decommissioning, etc.)
 - And fractional contribution will increase as more energy grids decarbonize
 - Can be hard to get firm numbers on embodied emissions
- When energy emissions are low, most emissions-efficient use is to run as fast as possible irrespective of energy cost
 - Get the most out of the embodied emissions before service is decommissioned
- However, this is a less energy-efficient approach to running an HPC service
- Tension between minimising total carbon emissions and minimising energy usage

Example: ARCHER2



- Estimates from UKRI DRI Net Zero project suggest around 1100 kgCO₂e per compute node
- Using this figure and ignoring other components for simplicity
 - 5860 compute nodes
 - Total embodied emissions estimate = 6,446,000 kgCO₂e

Scenario	gCO ₂ /kWh	Energy Emissions: per annum ¹ (kgCO ₂)	Energy Emissions: 5 years (kgCO ₂)	Embodied Emissions (kgCO ₂ e)	% Total emissions over 5 years
Green energy	~0	~0	~0	6,446,000	0%
South Scotland	48 ²	1,261,440	6,307,200	6,446,000	49%
UK	268 ³	7,043,040	35,215,200	6,446,000	85%
World	441 ³	11,589,480	57,947,400	6,446,000	90%

¹ Assuming 3 MW power draw

² Median value from 12 months: 1 Apr 2022 – 31 Mar 2023. <https://electricityinfo.org/>

³ <https://ourworldindata.org/grapher/carbon-intensity-electricity>

ARCHER2 is currently on the "Green energy" scenario so all emissions are embodied emissions

Why consider energy efficiency?



- Increasing in importance in the Exascale era as both energy usage and costs rise
- Total Cost of Ownership of HPC centres used to be dominated by capital costs but energy costs may now make up a significant fraction
- Can maximise "science per kWh"
- For the rest of this talk, we focus on reducing energy and power as these have practical impacts:
 - Reduces carbon emissions from systems that have already been procured
 - Reduces running costs and TCO
 - Increases control over power demand

Dr Alfonso Bueno Orovio

ARCHER2 power draw




Historical power draw measurements



Power draw of all compute cabinets (Mountain) is logged into a Graphite database and visualized using Grafana

- Power draw before any changes made
- Utilisation on ARCHER2 is consistent – just over 90%
- Mean power draw from cabinets: 3220 kW
- Measurements taken from the chassis management infrastructure in Mountain cabinets



Power draw by component



Estimated loaded power draws for ARCHER2 components:

- Some values measured by experiments and others provided by HPE engineers

Component	Notes	Idle (each)	Loaded (each)	Approx. %
Compute nodes	5860 nodes	1350 kW (0.23 kW)	3000 kW (0.51 kW)	80%
Slingshot interconnect	768 switches	100-200 kW (0.10-0.25 kW)	540 kW (0.70 kW)	10%
Other Cabinet Overheads	23 cabinets	100-200 kW (4.3-8.7 kW)	210 kW (9.1 kW)	6%
Coolant Distribution Units	6 CDUs	96 kW (16 kW)	96 kW (16 kW)	3%
File systems	5 file systems	40 kW (8 kW)	40 kW (8 kW)	1%
Service nodes	Negligible	-	-	
Total		1800 kW	3900 kW	

- Energy use dominated by compute cabinets; storage power not important
- Idle power draw of compute nodes is high – likely dominated by memory and NIC
- Switch power draw has a large amount of uncertainty as they are not instrumented


Dr Sam Azadi

Reducing power draw/energy use



Power/Performance Determinism

- In May 2022 the ARCHER2 compute nodes had a CPU BIOS setting changed from *Power Determinism* mode to *Performance Determinism* mode
- *Performance Determinism* keeps node performance more in-sync
 - Performance of multi-node parallel applications is determined by slowest node
 - Any extra power draw for performance above the slowest node is wasted power



<https://www.amd.com/system/files/2017-06/Power-Performance-Determinism.pdf>

Impact on application performance



Application benchmark	Number of nodes	Performance ratio PerfMode:PowerMode	Energy ¹ ratio PerfMode:PowerMode
CASTEP Al Slab	16	0.99	0.94
OpenSBLI TGV 1024 ³	32	1.00	0.90
VASP TiO ₂	32	0.99	0.93

¹Energy measured from on-node energy use counters – only reflects node energy use

- Performance impact is generally low – expected to be lower where more nodes are used
- Energy savings measured using cabinet power in line with energy savings measured on compute nodes
 - Suggests that overheads on top of compute node power do not affect conclusions

CPU Frequency – impact on power draw




Changed on 12 Dec 2022

Default CPU frequency:

- Before: 2.25 GHz (can turbo boost)
 - Typically boosts to ~2.8 GHz when all cores running intensively
- After: 2.00 GHz (no turbo boost)
- Some applications kept at original 2.25 GHz setting (with turbo boost)

Freed up significant power on the local electricity grid during period of potential electricity shortages



CPU Frequency – impact on performance



Application benchmark	Research areas	Nodes:PPN:TPP	Performance ratio 2.0 GHz:2.25 GHz	Node Energy ratio 2.0 GHz:2.25 GHz
VASP CdTe	Materials science, Mineral physics	8:128:1	0.95	0.88
GROMACS 1400k atoms	Biomolecular simulation	3:128:1	0.83	0.92
CP2K H2O 2048	Materials science	4:16:8	0.91	0.93
LAMMPS Ethanol	Materials science, Engineering, Biomolecular modelling	4:128:1	0.74	0.92
CASTEP Al Slab	Materials science	4:128:1	0.93	0.88
ONETEP hBN-BP-hBN	Materials science	4:16:8	0.92	0.82
Nektar++ TGV 128 DoF	Engineering	2:128:1	0.80	0.80

- All applications are more energy efficient at 2.0 GHz
- Looking at cost-efficiency would suggest:
 - Frequency set to 2.25 GHz: GROMACS and LAMMPS, Nektar++ [due to increased residency costs]
 - Frequency set to 2.0 GHz: VASP, CASTEP, ONETEP, CP2K
- Default frequency: 2.0 GHz with strong advice to users to test impact on their software

CPU Frequency – impact on performance



- What is the impact on energy use beyond just node energy use?
- Reserved a full cabinet (256 nodes) and filled with copies of benchmarks
- Initially focussed on applications which would be running at 2.0 GHz

Experiment	Cabinet energy use (kWh) ¹	Node energy use (kWh) ²	Overheads (kWh)	% Overheads	Cabinet ratio to 2.25 GHz	Node ratio to 2.25 GHz
8-node VASP, 256 nodes, 2.25 GHz	43.9	35.3	8.6	19.6%		
8-node VASP, 256 nodes, 2.00 GHz	38.5	30.4	8.1	21.0%	0.88	0.86

Experiment	Cabinet energy use (kWh) ¹	Node energy use (kWh) ²	Overheads (kWh)	% Overheads	Cabinet ratio to 2.25 GHz	Node ratio to 2.25 GHz
4-node ONETEP, 256 nodes, 2.25 GHz	128.2	108.3	19.8	15.5%		
4-node ONETEP, 256 nodes, 2.00 GHz	107.8	88.5	19.3	17.9%	0.84	0.82

¹ Calculated from instantaneous cabinet power draw measurements during benchmark runtime

² Sum of energies from all calculations in set that filled 256 nodes

- Energy savings measured at the node level clearly propagate to full cabinet energy use
 - Cabinet energy use includes interconnect switches and power overheads

Understanding power draw

- Used single cabinet reservations to try and understand power draw better
 - 256 nodes, 32 switches
- Run enough copies of benchmarks to fill 256 nodes – all at 2.25 GHz with turbo-boost enabled
- Compare cabinet power draw to compute node power draw (from on-node counters)

Experiment	Median node power draw	Total node power draw	Cabinet power draw	Non-node power draw	% Overhead compared to node power draw
Idle	230 W	58.9 kW	75.6 kW	16.7 kW	28%
1-node HPL	513 W	131.3 kW	150.8 kW	19.5 kW	15%
8-node VASP	497 W	127.2 kW	149.2 kW	22.0 kW	17%
16-node OSU Alltoall	489 W	125.1 kW	156.7 kW	31.6 kW	20%

- Non-node power draw overheads increase as communication intensity increases
- Information from HPE suggests a maximum per-switch power draw of 700 W
 - Gives a figure of 22.4 kW for 32 switches
 - Assuming OSU Alltoall hits this maximum power draw, other overheads are around 9.2 kW per cabinet for this experiment

Dr. Marco Rosti

Summary



Lessons learned



- High utilisation levels are critical for efficiency due to high idle power draw
 - The sector should investigate ways to reduce idle power draw of components
- Instrumentation of energy use needs to improve
 - Compute nodes are generally well covered but other key components (e.g., switches) are not
 - Makes it challenging to fully understand energy use or to introduce energy-based charging
- High quality information from vendors on embodied carbon associated with hardware is critical for good operational decision making
 - The current level of information is generally poor
- Need to know what your priorities are in order to make appropriate choices
 - Carbon emissions, energy, power, cost,...

Summary



- Changes which are quick to implement can have a large effect on energy use
- Gives flexibility to respond to particular requirements
 - Being asked to reduce demands on grid during specific periods
 - Reducing power when cooling infrastructure is under pressure
- Changing the CPU BIOS setting saves energy for large jobs and has negligible impact on performance
- Reducing the default processor frequency is worth considering
 - All application benchmarks showed lower energy use at 2.0 GHz
- On ARCHER2, we reduced energy usage by around 700 kW (21%)
 - With only modest impact on performance
 - Reducing demand on the power grid over winter
 - Making significant savings on running costs

Any questions?

